

DEL AV	CIDCLUT	LOAD CONTROLLED		DEMARKO
RELAY	CIRCUIT	LOAD CONTROLLED	SWITCH/SENSOR	REMARKS
R1	1N4A-1	EG LAB AND SHOP AREA INNER LAMPS	SMTCH S1	NOTE 6
R2	1N4A-1	EG LAB AND SHOP AREA OUTER LAMPS	SMTCH S2	NOTE 6
R3	1N4A-3	UPS/BATTERIES LAB INNER LAMPS	SMTCH S3	NOTE 6
R4	1N4A-3	UPS/BATTERIES LAB OUTER LAMPS	SMTCH S4	NOTE 6
R5	1N4A-7	WAREHOUSE/STORAGE 101 INNER LAMPS	SMTCH S5	NOTE 6
R6	1N4A-7	WAREHOUSE/STORAGE 101 OUTER LAMPS	SWTCH S6	NOTE 6
R7	1N4A-9	TEST, MOD. KITS, JAN., HALL, FIRE RISER	NONE	NOTE 6
R8	1N4A-9	EXTERIOR WALL PACKS, CANOPY LIGHTS	NOTE 4	NOTE 7
R9	1N4A-11	PARKING LOT	NOTE 4	NOTE 7
R10		SPARE		
R11		SPARE		
R12		SPARE		
R13		SPARE		
R14		SPARE		
R15		SPARE		
R16	1E4A-4	EXTERIOR EMERGENCY EGRESS LIGHTS	NOTE 4	INPUT A, NOTE 7
R17		SPARE		
R18		SPARE		
NS1	1N4A-1	HOT FOR ELCU-100 NORM. POWER SENSING		NOTE 1
NS2	1N4A-3	HOT FOR ELCU-100 NORM. POWER SENSING		NOTE 1
NS3	1N4A-7	HOT FOR ELCU-100 NORM. POWER SENSING		NOTE 1
NS34	1N4A-9	HOT FOR ELCU-100 NORM. POWER SENSING		NOTE 1
	l			

RELAY PANEL "LRP" NOTES:

- 1. NONSWITCHED CIRCUITS SHALL PASS THROUGH RELAY PANEL DIRECTLY TO PANELBOARD. AND
- SHALL NOT BE SWITCHED BY A RELAY. 2. PROVIDE PHOTOCELL COMPATIBLE WITH RELAY PANEL
- 3. PROVIDE ASTRONOMIC TIME CONTROL MODULE.
- 4. PHOTOCELL ON/TIME SWITCH OFF
- 5. INPUT "A" SHALL BE CONNECTED TO AN AUXILIARY CONTACT IN ATS2. LIGHTS SHALL BE FORCED ON UPON LOSS OF NORMAL POWER. PROVIDE TIME DELAY RELAY IF REQUIRED FOR THE CONTROL PANEL TO ACKNOWLEDGE THE "EMERGENCY ON" COMMAND.
- 6. CIRCUIT SHALL BE ACTIVE FROM 6 AM TO 6 PM. AT END OF DAY PROVIDE FLICK WARN. TIME SHALL BE EXTENDED BY ANY ONE OF THESE SWITCHES: LRP(S5), LRP(S6), LRP(S7).
- 7. DO NOT FLICK WARN THIS CIRCUIT.
- 8. PROVIDE WARNING LABEL TO READ: "THIS PANEL IS SERVED FROM PANELS '1N4A' AND "1E4A" 9. RE: "LOW VOLTAGE LIGHTING RELAY PANEL DETAIL," F/E-402.
- 10. PROVIDE JOHNSON CONTROLS METASYS BUILDING CONTROL INTERFACE MODULE
- FOR DIRECT CONTROL FROM DATABUS. 11. CONNECT TO JOHNSON CONTROLS METASYS SYSTEM DRY CONTACT FOR FLICKWARN TO OFF.
- 12. PANEL SHALL BE WATT STOPPER OR GE TLC.

4' FLUORESCENT STRIP ABOVE DOOR LITHONIA #Z 2 28T5 MVOLT GEB10PS 4' INDUSTRIAL FLUORESCENT WITH WIRE GUARD SUSPEND 9'-0" AFF | 3 - F28W/T5/841/ECO LITHONIA #EJ 3 28T5 277 1/3 GEB10PS WGEJZ 1'X4' FLANGED MOUNTED RECESSED FLUORESCENT TROFFER SHEETROCK 2 - F28W/T5/841/ECO LITHONIA #SP5 F 2 28T5 A12125 MVOLT GEB10PS EXTERIOR COMPACT FLUORESCENT WALL PACK 7'-4" AFF BOF 1 - F42TBX/841/ECO LITHONIA#WSTM 42TRT MD 277 DNAT L/LP COMPACT FLUORESCENT DOWNLIGHT SOFFI 1 - F42TBX/841/ECO GOTHAM #AFV 42TRT 8AR 277 EXTERIOR HPS WALL PACK WALL MOUNT 1 - LU70/MED/ECO LITHONIA#WST 70S FT 277 DNAT L/LP 20'-0" AFF TOF, UNO. EXTERIOR HPS WALL PACK - LU200/ECO/NC WALL MOUNT ITHONIA#TWF2 200S 277 DNAT L/LP 16'-0" AFF TOF THERMOPLASTIC EMERGENCY LIGHT WITH 5.4W HALOGEN LAMPS SURFACE MOUNT PROVIDED LITHONIA#ELM2 8'-0" AFF EM2 HAZARDOUS AREA EMERGENCY LIGHT RE: PLANS PROVIDED .ITHONIA#ELM2 SINGLE FACE LED EXIT LIGHT ABOVE DOOR, UNO. PROVIDED LITHONIA#LE S W 1 R 120/277 EL N SD 400W HPS SHOEBOX POLE 1 - LU400 ITHONIA#KVF2 400S SR4WFL 277 RP09 L/LP 250W HPS SHOEBOX POLE 1 - LU250 LITHONIA#KVF2 250S SR3FL 277 RP09 L/LP

IGHTING FIXTURE SCHEDULE GENERAL NOTES:

- A. ALL FLUORESCENT BALLASTS SHALL BE ELECTRONIC, UNO. B. A SINGLE BALLAST SHALL BE PROVIDED FOR EACH FIXTURE, UNO.
- C. ALL ELECTRONIC BALLASTS SHALL OPERATE AT NOT MORE THAN 10% TOTAL HARMONIC DISTORTION (THD).
- D. ALL ELECTRONIC BALLASTS SHALL HAVE A NOMINAL BALLAST FACTOR OF 0.875 OR GREATER.
- E. ALL BALLASTS (FLUORESCENT & HID) SHALL BE HIGH POWER FACTOR.
- F. COORDINATE LAY-IN FIXTURES WITH CEILING GRID SIZE AND STYLE PROVIDED. G. ALL COMPACT FLUORESCENT BALLASTS SHALL BE PROVIDED WITH "END OF LIFE" SHUTDOWN PROTECTION.

LIGHTING FIXTURE SCHEDULE KEYED NOTES:

- *1. WHERE PLANS CALL FOR MULTI-LEVEL SWITCHING, PROMDE FIXTURES WITH SEPARATE BALLASTS FOR INBOARD AND OUTBOARD LAMPS.
- *2. WHERE PLANS CALL FOR MULTI-LEVEL SWITCHING, PROVIDE FIXTURES WITH STEP DIMMING BALLASTS FOR DUAL-LEVEL SWITCHING. *3. PROVIDE 35' ROUND TAPERED STEEL POLE. LITHONIA #RTS 35 7-3B DM19 DDB
- *4. COORDINATE EXACT MOUNTING HEIGHT WITH ARCHITECT.

STORAGE BUILDING

NORTH

STORAGE BUILDING

- 1. SWITCH INNER AND OUTER LAMPS SEPARATELY THIS ROOM.
- 2. PHOTOCELL MOUNTED 11'-6" AFF, FACING NORTH. RE: "PHOTOCELL DETAIL," G/E-402. WIRE TO RELAY PANEL "LRP".
- 3. MOUNT EMERGENCY LIGHT TO WALL 8'-0" AFF.
- 4. FIXTURE MOUNTED ON WALL AT 23'-0" AFF.
- 5. LOCATE FIXTURE IN CLEAR VIEW OF AUTOMATIC TRANSFER SWITCH "ATS-2."
- 6. MOUNT FIXTURE TO CEILING.
- 7. EMERGENCY LIGHT "EM2." MOUNT FIXTURE ON WALL ABOVE DOOR.
- 8. MOUNT EMERGENCY LIGHT TO STRUCTURE.
- 9. RE: DETAIL C/E-402.
- 11. RE: DETAIL E/E-402.
- 12. 3 #16, 1/2" C.
- 13. SWITCH FOR LOCAL CONTROL OF CANOPY LIGHTS.
- 14. SWITCH FOR LOCAL CONTROL OF MECHANICAL YARD LIGHT.
- 15. HOMERUN TO <u>LRP</u>(S6,S7).

- 7 INFRARED SENSOR WITH SWIVEL BASE. MOUNTED ON CEILING.
- \$0S WALL BOX MOUNTED DUAL TECHNOLOGY OCCUPANCY SENSOR. WATT STOPPER #DW-100-I.
- POWER PACK MOUNTED ABOVE ACCESSIBLE CEILING. WATT STOPPER #BZ-100.
- ELCU EMERGENCY LIGHTING CONTROL UNIT IN NEMA 1 BOX MOUNTED ABOVE ACCESSIBLE CEILING. WATT STOPPER #ELCU.
- NORMAL POWER CIRCUITING.
- ____ EMERGENCY POWER CIRUITING ROUTED IN SEPARATE CONDUIT FROM NORMAL POWER.

OCCUPANCY SENSOR NOTES:

- 1. EXACT MOTION SENSOR LOCATIONS AND AIMING SHALL BE DETERMINED BY THE MANUFACTURER'S SPECIFICATIONS AND BASED ON FINALIZED
- DUCTWORK AND FURNITURE PLANS. 2. ULTRASONIC OR DUAL TECHNOLOGY SENSORS SHALL NOT BE MOUNTED

CLOSER THAN 6'-0" FROM AIR SUPPLY OR RETURN REGISTERS.

3. CONTRACTOR SHALL ADJUST SENSORS FOR OPTIMUM PERFORMANCE.



Horner Associates Engineers, Inc. 1306 Commerce Dr, Norman, OK 73071 Certificate of Authorization No. CA 3520, Expires 6/30/2011

nfo@haeinc.com Ph (405) 801-2528 Fax (405) 801-2529 COPYRIGHT (C) 2011 HORNER ASSOCIATES ENGINEERS, INC. ALL RIGHTS RESERVED



ARCHITECTURE PLANNING INTERIORS REES PLAZA AT EAST WHARF 9211 LAKE HEFNER PARKWAY, SUITE 300 OKLAHOMA CITY, OKLAHOMA 73120 P: 405.942.7337 F: 405.948.1261

Mechanical Engineer 050 Engineering Company 228 Robert S. Kerr Ave, Suite 515

Oklahoma City, OK 73102 P: 405.236.2030 F: 405.239.6101 Electrical Engineer

Horner Associates Engineers, Inc. 1306 Commerce Drive

Norman, OK 73071 P: 405.801.2528 F: 405.801.2529

Civil Engineer **MacArthur Associated Consultants**

3033 NW 63rd St., Ste. 250E Oklahoma City, OK 73116 : 405.848.2471 F: 405.848.2474 Structural Engineer

Zahl-Ford, inc. 8411 S. Walker

Oklahoma City, OK 73139 P: 405.634.3393 F: 405.634.6414

DEPARTMENT OF TRANSPORTATION FEDERAL AVIATION ADMINISTRATION MIKE MONRONEY AERONAUTICAL CENTER - OKLAHOMA CITY, OKLAHOMA PSL - POWER SERVICES LABORATORY

100% SUBMITTAL

LIGHTING PLAN

Construction Work Request No: 09-018745

PPROVED BY Rees Associates Jon Berkman May 26, 2011 BLP | FACILITY MANAGEMENT | DRAWING NO.

AMP-400 08-008257